FIRE SAFETY MANAGEMENT – FIRE RISK ASSESSMENT

STITHIANS SHOW 2025

Name of Company/Organisation:					
Item	Question	Yes	No	N/A	Comments
1	Do you have a person responsible for fire safety in your				
	company? If so, please add name in Comments				
	section.				
2	Do you have a nominated deputy? If so, please add				
	name in Comments section.				
3	Have your staff (including temporary staff/volunteers)				
	been instructed in how to raise the alarm?				
4	Do you have sufficient fire extinguishers available of a				
	suitable type and size?				
	If you are using LPG on site a minimum of a 5kg powder				
	extinguisher must be provided for every two LPG				
	cylinders.				
5	Have your fire extinguishers been inspected in the last				
	12 months by a competent person/company?				
6	Do your staff (including temporary staff/volunteers)				
	know how to use a fire extinguisher?				
7	Will your fire extinguisher/s be positioned where it is				
	available for easy use? i.e. not in your vehicle.				
8	Are your fire exit routes kept clear and not obstructed by				
	vehicles/stock/equipment etc?				
9	Are all staff (including temporary staff/volunteers)				
	aware of the importance of keeping the area tidy and				
	free from trip hazards?				
10	Do you have training records for all staff (including				
	temporary staff/volunteers)? If so, they should be				
4.4	available for inspection, if required.				
11	Have all electrical items been PAT tested? (Paperwork				
40	may be requested).				
12	Have all gas appliances been inspected by a Gas Safe registered engineer? (Paperwork may be requested).				
40	Will you be using LPG? If so, will this be stored outside	*			
13	your tent and secured so it cannot be knocked over or	^			
	tampered with? (It must still be accessible in an				
	emergency).				
14	Will you be using a Generator? If so, are you aware that			+ +	
14	petrol generators are NOT permitted on site?				
15	Are you aware that you must not sell/exhibit certain				
'3	items, e.g. fireworks, garden flares, lit tea lights or				
	candles (unlit tea lights and candles are permitted).				
16	Have you read the terms and conditions for			+ +	
.0	exhibiting/trading at the Show? If not, please ensure				
	you do before the event.				

*The maximum number of LPG cylinders on our stand will be:

Туре	No./Size
Butane	
Propane LPG	
Patio Gas	